Performance Profile Sheet (Page 1 of 2)

NCCER Training

Craft: Pipeline Mechanical Level 3

Module: CT23_2-17

Module Title: Inspect, Test, and Calibrate Relief Valves



Trainee Name:		
Training Program Sponsor:		
Instructor:		

Rating Levels: (1) Passed: performed task (2) Failed: did not perform task

Also, list the date the testing for each task was completed.

Recognition: When testing for the NCCER Training Program, be sure to record Performance testing results on the

Registration of Training Modules form, and submit the results to the Training Program Sponsor.

OBJECTIVE	TASK	RATING	DATE	START TIME	END TIME
2	Inspect, test, and calibrate relief valves (CT23_2-17).				
	Identify potential abnormal operating conditions that may occur during performance of this CT, and know the appropriate actions to take in response to them.				
	Utilize the appropriate personal protective equipment according to relevant company procedures.				
	Verify location and accessibility of relief valve to be inspected, and verify the device number, device type, manufacturer, and nameplate data.				
	Notify control center and/or affected personnel before work begins.				
	Follow associated task-specific procedures (if applicable).				
	Verify the correct device setpoint, determine the correct test medium and method, and obtain the necessary test equipment.				

Performance Profile Sheet (Page 2 of 2)

NCCER Training

Craft: Pipeline Mechanical Level 3

Module: CT23_2-17

Module Title: Inspect, Test, and Calibrate Relief Valves



OBJECTIVE	TASK	RATING	DATE	START TIME	END TIME
	Perform a complete visual inspection and make any necessary repairs or replacements before continuing with the procedure.				
	Connect the appropriate test equipment. Apply the test medium at the correct pressure to verify the device's "as-found" setpoint and/or operating range. Document the results.				
	If required, reapply the test medium for the desired setpoint and/or operating range.				
	Document the "as-left" setpoint and/or operating range, following company procedures. Disconnect all test equipment.				
	Put all safety devices back in service. Remove lockout/tagout, if applicable.				
	Return the system to its normal operating state. Perform a function test to confirm that everything is working properly.				
	Apply security seal to the relief valve as required by procedures (if applicable).				
	Notify control center and/or affected personnel after completion of work.				
	Complete appropriate documentation as required by operator's procedures.				