

# Performance Profile Sheet (Page 1 of 2)

NCCER Training

Craft: Pipeline Electrical and Instrumentation Level 2  
 Module: CT25\_1-17  
 Module Title: Inspect, Test and Calibrate Pressure Switches



Trainee Name:

Training Program  
 Sponsor:

Instructor:

Rating Levels: (1) Passed: performed task (2) Failed: did not perform task  
 Also, list the date the testing for each task was completed.

Recognition: When testing for the NCCER Training Program, be sure to record Performance testing results on the Registration of Training Modules form, and submit the results to the Training Program Sponsor.

OBJECTIVE	TASK	RATING	DATE	START TIME	END TIME
2	Inspect, test, and calibrate pressure switches (CT25_1-17).				
	Identify potential abnormal operating conditions (AOCs) that may occur during performance of this CT, and know the appropriate actions to take in response to them.				
	Utilize the appropriate personal protective equipment according to relevant company procedures.				
	Verify certification that test equipment has been calibrated prior to performing calibrations.				
	Verify device set point for switches prior to performing calibration.				
	Determine correct test medium and range to be used for testing.				
	Notify control center and/or affected personnel before work begins.				

**Craft:** Pipeline Electrical and Instrumentation Level 2  
**Module:** CT25\_1-17  
**Module Title:** Inspect, Test and Calibrate Pressure Switches



OBJECTIVE	TASK	RATING	DATE	START TIME	END TIME
	Isolate the pressure switch from the process system and inspect all connection for leakage.				
	Apply test medium pressure and verify device setpoint or range "as found" and document the results.				
	Re-apply test medium for desired setpoint or range and adjust if necessary according to device manufacturer's specifications to establish desired setpoint. Document final setpoint setting(s) "as left".				
	Notify control center and/or affected personnel after completion of work.				
	Complete appropriate documentation as required by operator's procedures.				