

Performance Profile Sheet (Page 1 of 2)

NCCER Training

Craft: Pipeline Electrical and Instrumentation Level 2
 Module: CT25_2-17
 Module Title: Inspect, Test, and Calibrate Pressure Transmitters



Trainee Name:

Training Program
 Sponsor:

Instructor:

Rating Levels: (1) Passed: performed task (2) Failed: did not perform task
 Also, list the date the testing for each task was completed.

Recognition: When testing for the NCCER Training Program, be sure to record Performance testing results on the Registration of Training Modules form, and submit the results to the Training Program Sponsor.

OBJECTIVE	TASK	RATING	DATE	START TIME	END TIME
2	Inspect, test, and calibrate pressure transmitters (CT25_2-17).				
	Identify potential abnormal operating conditions (AOCs) that may occur during performance of this CT, and know the appropriate actions to take in response to them.				
	Utilize the appropriate personal protective equipment according to relevant company procedures.				
	Verify certification that test equipment has been calibrated prior to performing calibrations.				
	Verify range of transmitter prior to performing calibration.				
	Determine correct test medium and the range to be used for testing.				
	Notify control center and/or affected personnel before work begins.				

Performance Profile Sheet (Page 2 of 2)

NCCER Training

Craft: Pipeline Electrical and Instrumentation Level 2
Module: CT25_2-17
Module Title: Inspect, Test, and Calibrate Pressure Transmitters



OBJECTIVE	TASK	RATING	DATE	START TIME	END TIME
	Isolate the pressure transmitter from the process system and inspect all connections for leakage.				
	Apply test medium pressure and verify device setpoint or range "as found". Verify pressure transmitters at zero, mid, and full scale calibration points. Document results "as found."				
	Re-apply test medium for zero, mid-scale and full scale. Adjust if necessary according to device manufacturer's specifications to establish desired calibration.				
	Verify activation of digital control output and/or operation of the end device at the established setpoint. Document final setpoint settings "as left."				
	Notify control center and/or affected personnel after completion of work.				
	Complete appropriate documentation as required by operator's procedures.				