

Craft: Pipeline Electrical and Instrumentation Level 2
 Module: CT44_4-17
 Module Title: Inspection, Testing, and Corrective and Preventative Maintenance of Tank Gauging for Hazardous Liquid Leak Detection



Trainee Name:

Training Program
 Sponsor:

Instructor:

Rating Levels: (1) Passed: performed task (2) Failed: did not perform task
 Also, list the date the testing for each task was completed.

Recognition: When testing for the NCCER Training Program, be sure to record Performance testing results on the Registration of Training Modules form, and submit the results to the Training Program Sponsor.

OBJECTIVE	TASK	RATING	DATE	START TIME	END TIME
2	Inspect, test, and perform corrective and preventative maintenance of tank gauging for hazardous liquid leak detection (CT44_4-17).				
	Identify potential abnormal operating conditions that may occur during performance of this CT, and know the appropriate actions to take in response to them.				
	Utilize the appropriate personal protective equipment (PPE) according to relevant company procedures.				
	Determine the device's number and nameplate data and confirm the calibration point values for the device.				
	Notify control center and/or affected personnel before work begins.				
	Visually inspect the device and any associated equipment.				

Craft: Pipeline Electrical and Instrumentation Level 2
Module: CT44_4-17
Module Title: Inspection, Testing, and Corrective and Preventative Maintenance of Tank Gauging for Hazardous Liquid Leak Detection



OBJECTIVE	TASK	RATING	DATE	START TIME	END TIME
	Confirm that anything that could disturb the tank is shut off, that inlets and outlets are closed, and that the liquid inside the tank is still.				
	Confirm the test equipment's current certification status.				
	Gauge the tank with a certified device (handline, etc.) and compare its result to the tank gauge output.				
	Calibrate the tank gauge following the manufacturer's procedure.				
	Perform all steps required to resume normal operation. Notify control center and/or affected personnel that the unit has been returned to normal operation.				
	Complete appropriate documentation as required by operator's procedures.				